



BULGARKONTROLA

BULGARKONTROLA SA -Sofia

Conformity Assessment Body for Construction Products

With identification number 14 and Permit № ПОССП-14 on 15.09.2016

Issued by Ministry of Regional Development and Public Works

CERTIFICATE OF CONFORMITY

14 – HYPBCIIICPB – 4330

Issued pursuant to Art. 14, par 1 and par. 2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

BRASS VALVES AND COMBINATION SANITARY MIXERS

Are designed for construction of water-supply pressure piping systems inside buildings with water for human consumption, with operating pressure PN 10 bar, maximum permissible temperature 90° C , with series, description, art. Nr and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

place on the market by

“FORMA VITA BULGARIA” S.A.

222A “Sixth September “Bul., 4000 Plovdiv, Bulgaria

Id 115870481

manufactured by

Zhejiang Bozhan Sanitary Ware Technology Co.LTD

International name (Shanghai Yuson Industry Co.LTD)

Intersectin of Nanping Road, Yongquan Town, Linhai City, Zhejiang Province, China

This certificate certifies that the product has been evaluated and meets national requirements set out in

BDS EN 200:2024

The Certificate was issued on **12/10/2026**, cancel the Certificate of № **14-HYPBCIIICPB-4145** from **21/11/2025** and remains valid until **11/10/2029**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia

Date: 12/10/2026

Director of "Conformity Assessment" Dept.

/T. Lyubenova/





1. Series, description, and art.

Series	Description	Art. Nr
Siena	Wall -mounted bath/shower mixer	7003
	Deck -mounted mixer for kitchen	7005
	Wall -mounted basin mixer	7006
		7006-1
		7006-2
Mesina	Wall -mounted bath/shower mixer	7003D
	Deck -mounted mixer for kitchen	7005D
	Wall- mounted basin mixer	7006D
		7006-1D
		7006-2D

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Leaktightness	
Leaktightness of the mixing valve and of the obturator under hydrostatic pressure upstream of the obturator with the obturator in the closed position	No leakage during the test, According to BDS EN 200:2024, item 10.3.2., table 7
Leaktightness of the mixing valve and of the obturator under hydrostatic pressure upstream of the obturator with the obturator in the open position	No leakage during the test, According to BDS EN 200:2024, item 10.4.3., table 7
Mechanical resistance	
Mechanical resistance of the mixing valve and of the obturator under hydrostatic pressure downstream of the obturator with the obturator in the closed position	No permanent deformation in any part of the mixing valve According to BDS EN 200:2024, item 11.3.2, table 8
Mechanical resistance of the mixing valve and of the obturator under hydrostatic pressure downstream of the obturator with the obturator in the open position	No permanent deformation in any part of the mixing valve According to BDS EN 200:2024, item 10.4.2., table 8
Hydraulic characteristics (flow rate)	4÷12 l/ min (with water saving) ≥ 9 l/ min (without water saving) BDS EN 200:2024, item 12.3.4., table 10 Annex C, table C1

Place: Sofia
Date: 12/10/2026

Director of "Conformity Assessment" Dept.

/T. Lyubenova/

